

## State of Kansas ADA Acceptance Record

Department of Administration, OFPM-DCC

This is not an approval of compliance to contract documents. The Project Architect/Engineer has primary responsibility for inspection to determine compliance with the contract documents. This is not a work directive or authorization. Contractor is to coordinate solution of deficiency with Project Architect/Engineer and to correct all noted deficiencies as directed by Project Architect/Engineer.

<b>Inspection Date:</b> <small>Click here to enter a date.</small>		<b>Inspector:</b> <small>Select</small>	
<b>Project Number:</b> <small>Click here to enter text.</small>		<b>Project Name:</b> <small>Click here to enter text.</small>	
<b>DCC A/E:</b>		<b>Agency:</b> <small>Click here to enter text.</small>	
<b>D = Deficiency (see notes)</b>		<b>A = Accepted</b>	
		<b>DC = Deficiency Corrected</b>	
		<b>NA = Not Applicable</b>	

<b>APPROACH &amp; ENTRANCE</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Site Arrival	At least 1 route that does not require use of stairs (ie: ramp, lift, 1:20 slope)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Parking	Adequate number of accessible spaces provided. 8'wide access aisle at least 5'1-25 (1), 26-50 (2), 51-75 (3), 76-100 (4) 100+ see standard 208.2	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Accessible Spaces	At least 1 van accessible space. 11'wide access isle at least 5'. 98" vertical clearance	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Access Aisles	Marked to discourage parking	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Parking Space Slope	No steeper than 1:48 in all directions	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Accessible Route	Access Aisle adjoins accessible route	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Accessible Spaces Identification	Sign provided. Bottom of sign at least 60" above ground. Provided with International Symbol	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Van Accessible Sign	Sign provided that reads accessible van	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>EXTERIOR ACCESSIBLE ROUTE</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Route	Stable, firm and slip resistant	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Route Width	At least 36" wide. Can narrow to 32" for max of 24", narrow portions shall be 48" from each other	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Route Length	Greater than 200' and less than 60" wide, passing space required no less than 60"x60	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Running Slope	No steeper than 1:20. Steeper than 1:20, treat as ramp and add edge protection and handrails	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cross Slope	No steeper than 1:48	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>CURB RAMPS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Curb Ramp	If accessible route crosses a curb, is there a curb ramp	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Running Slope	No steeper than 1:12	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cross Slope	Excluding flares, no steeper than 1:48	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Width	Excluding flares, is at least 36" wide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Level Landing	No steeper than 1:48 at least 36" long and as wide as ramp, less than 36' flares provided	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>RAMPS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Width	At least 36" wide, if handrails present measure between handrails	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface	Stable, Firm and slip resistant	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Running Slope	No steeper than 1:12. 3" rise 1:8 and 6" rise 1:10 permitted due to space limitations	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Landin	At least 60" long and as wide as the ramp at the top and bottom	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ramp Direction	If ramp changes direction is there a landing at least 60 x 60 inches	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Handrails	Required if rise is higher than 6"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Handrail Height	Between 34-38 inches above ramp surface	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Circular Rail	No less than 1 1/4" and no greater than 2" inches in diameter	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Non-Circular Rail	Perimeter is no less than 4" and no greater than 6 1/4" inches	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Handrail End	Extend at least 12" horizontally beyond the top and bottom of the ramp	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wheelchair, Casters, Crutch Tips	Surface of ramp extend at least 12" beyond the inside face of the handrail	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>ENTRANCE</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Main Entrance	Is main entrance accessible	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Alternate Entrance	If main entrance is not accessible is there an alternate entrance with same hours of use	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inaccessible Entrances	Have a sign indicating the nearest accessible entrance	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
International Symbol	Is there a sign located at the accessible entrance	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Clear Opening	At least 32" between face of door and stop with door opened 90 degrees	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Front Approach	Is there at least 18" of maneuvering clearance beyond latch side and 60" in depth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Threshold	If threshold is vertical no more than ¼" high	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Hardware	Operable with 1 hand, does not require tight grasping, twisting or pinching of the wrist	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Closure	Takes at least 5 secs to close from an openable 90 degrees to a position of 12 degrees form latch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Vestibule (2 doors)	Distance between doors is at least 48" plus the width of the doors when swinging into the space	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carpets/Mats	No higher than ½" thick	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>ACCESS TO GOODS &amp; SERVICES</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Direct Access	Provided to main floor, lobby and elevators	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>INTERIOR ACCESSIBLE ROUTES</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Accessible Route	At least 1 accessible route to all public spaces	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Cross Slope	No steeper than 1:48	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Projections	No more then 4" into the path of travel. ie. Drinking fountains, fire extinguishers ect	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Projections	More than 4", is bottom leading edge at 27" or lower or 80" or higher above floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Elevators/Lifts	Are available to all public areas	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>ELEVATORS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Dimensions	Is interior at least 54" deep by 36" wide and at least 12 sq. ft clear floor area	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
In-Car Controls	No less than 15" and no greater then 48" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
In-Car Parallel Approach Controls	Up to 54" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
In-Car Control Buttons	Raised Braille	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
In- Car Audible Signals	Sound provided as the car passes or is about to stop at a floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Floor ID Signs	Is there a sign on both door jambs identifying the floor. Is there a tactile Star	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tactile Star	Shall be provided on both jambs at the main entry level	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Text Characters	Raised and Braille	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Call Buttons	42" from middle of device to the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hall Lanterns	72" from middle of device to the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Signage	48" from baseline of lowest character and 60" to baseline of highest character	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>PLATFORMS / LIFTS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Assistance	Can it be used without assistance from others	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Approach	30" wide by at least 48" long space to reach controls of lift	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Lift Controls	No less than 15" and no greater than 48" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Inside lift Space	30" wide by at least 48" long	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
End Door	Opening is at least 32"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Side Door	Clear opening is at least 42"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>INTERIOR DOORS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Door Opening	At least 32" clear between the face of door and the stop, when door opened 90 degrees	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Front Approach	Is there at least 18" of maneuvering clearance beyond latch side and 60" in depth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Threshold	If threshold is vertical no more than ¼" high	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Hardware	Operable with 1 hand, does not require tight grasping, twisting or pinching of the wrist	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Operable Parts	No less than 34" and no greater than 48" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Force	Can be easily opened with less than 5lbs of force	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Closure	Takes at least 5 secs to close from an openable 90 degrees to a position of 12 degrees form latch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>ROOMS &amp; SPACES</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Aisles & Pathways	Are at least 36" wide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Route	Stable, firm and slip resistant	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Carpets/Mats	No higher than 1/2" thick	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>CONTROLS – LIGHT SWITCHES, ETC.</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Aisles & Pathways	At least 30" wide 48" long for forward or parallel approach	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Operable parts	No higher than 48" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Operation	Can be operated with 1 hand and without tight grasping, pinching or twisting the wrist	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>SEATING: ASSEMBLY AREAS/THEATER STYLE CLASSROOMS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Spaces	Adequate number of wheelchair spaces provided 4-25 (1), 26-50 (2), 51-150 (3), 151-300 (4), 300+ 221.2.1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Location	Spaces dispersed to allow location choices and viewing angles equivalent to other seating	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Seating Clear Line of Sight	Have a clear line of sight over and between the heads of others in front of them	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Standing Clear Line of Sight	Have a clear line of sight over and between the heads of others in front of them	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Width	Wheelchair space is at least 36"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Adjoining Width	Two adjacent spaces are each at least 33' wide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Depth	Entered from front or rear it is at least 48" side entrance is 60"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Companion Seat	Is provided	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>SEATING: DINING RESTAURANTS &amp; CAFETERIAS / NON-EMPLOYEE WORK (LIBRARIES, CONFERENCE ROOMS)</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Route Width	At least 36" wide to accessible seating	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Accessible Surface	At least 28" no greater than 34" above the floor. Children at least 26" no greater than 30"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Forward Approach	At least 30" wide by at least 48" long for forward approach	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Knee Space	At least 27" high and at least 30" wide	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>SEATING: GENERAL – RECEPTION AREAS, WAITING ROOMS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Space	At least one space at least 36" wide by 48" long for person in wheelchair	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>BENCHES LOCKER DRESSING, FITTING ROOMS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Bench	At least one room with a bench is provided	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Bench Clear Floor Space	Clear floor space at least 30" wide by at least 48" long at the end of bench and parallel to short axis	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>FOOD SERVICE LINES – CAFETERIAS, SALAD BARS, EST-IN FAST FOOD</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Service Shelf	A Parallel Approach is provided	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Dispensing Device	A Parallel Approach is provided	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Service Shelf/Dispensing Device	No higher than 48" above the floor with or without an obstructed forward approach	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shallow Obstruction	No deeper than 10" w/ parallel approach and Service Shelf/Dispensing Device no higher than 48"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Shallow Obstruction	No deeper than 10" - 24" deep w/ parallel approach and Service Shelf/Dispensing Device no higher than 46"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
< 20" Obstruction	Floor Space extends under the obstruction, same depth as the obstruction. Shelf no higher than 48"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20"-25" Obstruction	Floor Space extends under the obstruction, same depth as the obstruction. Shelf no higher than 44"	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tray Slide	Top no less than 28" and no greater than 34" above floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

<b>TOILETS</b>		<b>D</b>	<b>A</b>	<b>DC</b>	<b>NA</b>
Directional Signs	Are there signs at inaccessible toilet rooms that give directions to accessible toilet rooms	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
International Symbol	Sign at the accessible toilet room with the International Symbol of Accessibility	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Signage	characters contrast with their backgrounds, raised, braille, on wall on latch side of door	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Clear Opening	At least 32" between face of door and stop with door opened 90 degrees	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Front Approach	Is there at least 18" of maneuvering clearance beyond latch side and 60" in depth	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Threshold	If threshold is vertical no more than 1/4" high	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Hardware	Operable with 1 hand, does not require tight grasping, twisting or pinching of the wrist	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Operable Parts	No less than 34" and no greater than 48" above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Force	Can be easily opened with less than 5lbs of force	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Door Closure	Takes at least 5 secs to close from an openable 90 degrees to a position of 12 degrees from latch	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mirror over lavatory	Bottom edge of the reflecting surface no higher than 40 inches above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Mirror not over lavatory	Bottom edge of the reflecting surface no higher than 35 inches above the floor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Coat Hook	No less than 15 inches and no greater than 48 inches above the floor	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Lavatory	Has a clear floor space for a forward approach at least 30 inches wide and 48 inches long	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Lavatory Clearance	No less than 17 inches and no greater than 25 inches of the clear floor space extend under the lavatory	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Lavatory Counter Height Top	No more than 34 inches above the floor to the top of the counter	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Lavatory Counter Bottom	At Least 27 inches above the floor to the bottom of counter	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toe Clearance	At least 9 inches high	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Pipes	All pipes below the lavatory insulated or otherwise configured to protect against contact	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Faucet Operation	Can faucet be operated without tight grasping, pinching, or twisting of the wrist	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Soap Dispenser & Hand Dryer	Above lavatories or counters 20"-25" deep no higher than 44". Above Lavatories less than 20" no higher than 48". No obstruction no higher than 48".	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Hand Dryer Operable Parts	Can hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Water Closet	Centerline no less than 16" and no greater than 18" from side wall or partition	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Water Closet Clearance	60" form the side wall and at least 56" from the rear wall	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Water Closet Height	No less than 17" and no greater than 19" from floor to top of the seat	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Side Grab Bars	No more than 12" from rear wall. At least 42" long. No less than 33" and No higher than 36" in height	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Grab Bars Projecting Objects	At least 1 1/2 " clearance between grab bar and projecting objects below. 12" above grab bar	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Rear Grab Bars	At least 36" long. Extends at least 12" from centerline of water closet and 24" on other end. 33" - 36" in height	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Flush Control	If hand operated no higher than 48" from floor	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Flush Control Operation	Operated without tight grasping, pinching or twisting of the wrist	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toilet Paper Dispenser	No less than 7" and no greater than 9" from front of water closet to centerline of dispenser	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toilet Paper Dispenser Outlet	No less than 15" and no greater than 48" above floor	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toilet Stall	Door opening at least 32" wide when door is opened 90 degrees.	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toilet Stall Front Approach	Is there at least 18" of maneuvering clearance beyond latch side and 60" in depth	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
Toilet Stall Door	The door is self closing	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>

Notes: